

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0948:102 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** World Electronics, 12233 NW 35th St., Coral Springs FL 33065  
Contact: Phil Barrett (888) 625-7533 \*

**DESIGN:** Model 2085B. Non-coded, march time, automatic, manual, sprinkler supervisory and waterflow for local, central station or proprietary fire alarm service (with Model 2100 board). Refer to listee's data sheet for detailed product description and operational considerations.

**OPTIONS:** Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as a control unit when used with separately listed compatible initiating and indicating devices. Intended for use with Wheelock Model ES series horns or horn/strobe units (CSFM Listing No. 7135-0785:107) when used for local alarm service. Central Station service requires Model 2085B control, Model 2100 dialer interface board. Proprietary service requires Model 2085B control unit, Model 2100 dialer interface board and a CSFM separately listed compatible proprietary unit which accepts dry contact inputs.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-04-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 4, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager